

SAFE AT HOME CHECKLIST

Use this list as a guide to identify home safety, fall hazards, and accessibility issues for the homeowner and family members. Home safety, fall prevention and accessibility modification interventions on the second page can help prioritize your work. Underline or use a highlighter to note problems and add comments.



1. EXTERIOR ENTRANCES AND EXITS

- ☐ Note condition of walk and drive surface, existence of curb cuts
- ☐ Note handrail condition, right and left sides
- ☐ Note light level for driveway, walk, and porch
- ☐ Check door threshold height
- ☐ Note ability to use knob, lock, key, mailbox, peephole, and package shelf
- ☐ Do door and window locks work easily?
- ☐ Are the house numbers visible from the street?
- ☐ Are bushes and shrubs trimmed to allow safe access?
- ☐ Is there a working doorbell?

2. INTERIOR DOORS, STAIRS, HALLS

- ☐ Note height of door threshold, knob, and hinge types; clear width door opening; determine direction that door swings
- ☐ Note presence of floor level changes
- ☐ Note hall width, adequate for walker/wheelchair
- ☐ Determine stair flight run—straight or curved
- ☐ Note stair rails—condition, right and left side
- ☐ Examine stairway light level
- ☐ Note floor surface texture and contrast
- ☐ Note if clutter on stairway

3. BATHROOM

- ☐ Are sink basin and tub faucets, shower control, and drain plugs manageable?
- ☐ Are hot water pipes covered?
- ☐ Is mirror height appropriate, sit and stand?
- ☐ Note ability to step in and out of the bath and shower
- ☐ Can resident use bath bench in tub or shower?
- ☐ Note toilet height; ability to reach paper, flush, and come from sit to stand posture
- ☐ Is space available for caregiver to assist?

COMMENTS:

4. KITCHEN

- ☐ Note overall light level, task lighting
- ☐ Note sink and counter heights
- ☐ Note wall and floor storage shelf heights
- ☐ Are under sink hot water pipes covered?
- ☐ Is there under counter knee space?
- ☐ Is there a nearby surface to rest hot foods on when removed from oven?
- ☐ Note stove condition and control locations (front or rear)
- ☐ Is there adequate counter space to safely prepare meals?

5. LIVING, DINING, BEDROOM

- ☐ Chair, sofa, bed heights allow sitting or standing?
- ☐ Do rugs have non-slip pad or rug tape?
- ☐ Chair available with arm rests?
- ☐ Able to turn on light, radio, TV; place a phone call from bed, chair, and sofa?

6. LAUNDRY

- ☐ Able to hand-wash and hang clothes to dry?
- ☐ Able to safely access washer/dryer?

7. BASEMENT

- ☐ Are the basement stairs stable and well lit?
- ☐ Is there any storage of combustible materials?

8. TELEPHONE AND DOOR

- ☐ Phone jack/cell phone location near bed, sofa, chair?
- ☐ Able to get phone, dial, and hear caller?
- ☐ Able to identify visitors, hear doorbell?
- ☐ Able to reach and empty mailbox?
- ☐ Wears neck/wrist device to obtain emergency help?
- ☐ Is there an answering machine?
- ☐ Is there a wireless phone system?
- ☐ Does the resident have a cell phone?

COMMENTS:

- 
 CONNECTS • SENIORS • WORKS

-
-
-

-
-
-
-
-
-

- [illegible]

[illegible]

HELP PREVENT FALLS—SAFETY ENHANCEMENTS, FALL PREVENTION AND ACCESSIBILITY MODIFICATION INTERVENTIONS THAT MAY HELP PRIORITIZE YOUR WORK.



1. EXTERIOR ENTRANCES

- ☐ Increase lighting at entry area
- ☐ Install stair rails on both sides
- ☐ Install door lever handles; double-bolt lock
- ☐ Install beveled, no step, no trip threshold
- ☐ Remove screen or storm door if needed
- ☐ Create surface to place packages when opening door
- ☐ Install peephole on exterior door
- ☐ Repair holes, uneven joints on walkway
- ☐ Provide non-slip finish to walkway surface
- ☐ Add ramp as needed
- ☐ Trim bushes and shrubs to provide clear view from doors and windows
- ☐ Trim low hanging branches

2. INTERIOR DOORS, HALLS, STAIRS

- ☐ Create clear pathways between rooms
- ☐ Apply color contrast or texture change at top and bottom stair edges
- ☐ Install door lever handle
- ☐ Install swing-clear hinges to widen doorway. Minimum width 32 inches
- ☐ Install beveled thresholds (max ½ inch)
- ☐ Replace or add non-slip surface to steps
- ☐ Repair or install stair handrails on both sides

COMMENTS:

3. BATHROOM

- ☐ Install swing-clear hinges to widen doorway. Minimum width 32 inches
- ☐ Install secure grab bars at toilet, bath, and shower
- ☐ Install adjustable-height, hand-held shower head
- ☐ Install non-slip strips in bath/shower
- ☐ Secure floor bathmat with non-slip, double-sided rug tape
- ☐ Adapt flush handle or install flush sensor
- ☐ Adapt or relocate toilet paper dispenser
- ☐ Round counter corners to provide safety
- ☐ Insulate hot water pipes if exposed
- ☐ Create sitting knee clearance at basin by removing vanity door and shelves underneath
- ☐ Install mirror for sitting or standing view
- ☐ Install good-quality non-glare lighting
- ☐ Install shower with no threshold if bathing abilities are severely limited
- ☐ Elevate toilet height by adding under seat riser, portable seat, or raising toilet at the base

4. KITCHEN

- ☐ Increase task lighting at sink, stove, etc.
- ☐ Install D-type cupboard door handles
- ☐ Install adjustable shelving to increase access to upper cabinets
- ☐ Increase access to under counter storage space by installing pull-out units
- ☐ Insulate hot water pipes if exposed
- ☐ Install hot proof surface near oven
- ☐ Install switches and outlets at front of counter
- ☐ Install pressure-balanced, temperature-regulated, lever faucets
- ☐ Expand counter surface
- ☐ Create sitting knee clearance under work sites by removing doors or shelves
- ☐ Improve color contrast of cabinet and counters surface edges for those with low vision
- ☐ Add tactile and color-contrast controls for those with low vision
- ☐ Provide sturdy step stool with handrail
- ☐ Clean or install new range hood

HELP PREVENT FALLS: SAFETY ENHANCEMENTS, FALL PREVENTION AND ACCESSIBILITY MODIFICATION INTERVENTIONS THAT MAY HELP PRIORITIZE YOUR WORK.



5. LIVING, DINING, BEDROOM

- ☐ Widen or clear pathways within each room by rearranging furniture
- ☐ Secure throw and area rug edges with double-sided tape
- ☐ Improve access to and from chairs and beds by inserting risers under furniture legs
- ☐ Use side bedrail or chairs with armrests
- ☐ Enlarge lamp switch or install touch-control lamp at bedside
- ☐ Install adjustable closet rods, shelving, and light source for better storage access
- ☐ Install vertical pole adjacent to chair and sofa
- ☐ Raise furniture to appropriate height using leg extender products
- ☐ Install uniform level floor surfaces using wood, tile, or low-pile rugs
- ☐ Install telephone jack and/or cell phone charger near bed and favorite chair

6. LAUNDRY

- ☐ Build a counter for sorting and folding clothes
- ☐ Adjust clothesline to convenient height
- ☐ Relocate laundry appliances
- ☐ Clean dryer vent or replace with metallic hose

7. BASEMENT

- ☐ Identify and eliminate sources of water in basement (usually gutters or plumbing)
- ☐ Add additional lighting as needed
- ☐ Remove combustible materials and hazardous waste
- ☐ Clear pathway to utilities

8. TELEPHONE AND DOOR

- ☐ Install wireless or cell phone system near bed, sofa, and chair
- ☐ Install peephole at convenient height
- ☐ Install flashing light or sound amplifier to indicate ringing doorbell for those with visual or hearing impairments
- ☐ Install mailbox at accessible height

9. STORAGE SPACE

- ☐ Install lights inside closet
- ☐ Install adjustable closet rods and shelves

- ☐ Install bi-fold or pocket doors

10. WINDOWS

- ☐ Install handles and locks that are easy to grip, placed at appropriate heights
- ☐ Replace windows or storms that are not functional

11. ELECTRICAL OUTLETS AND CONTROLS

- ☐ Install light fixtures or outlet for lamps
- ☐ Install switches at top and bottom of stairs
- ☐ Install Ground Fault outlets in kitchen and bathroom
- ☐ Install wireless light switches where needed

12. HEAT, AIR, LIGHT, SMOKE, CARBON MONOXIDE, WATER TEMP CONTROLS

- ☐ Install smoke/CO alarms, fire extinguishers
- ☐ Replace thermostat with easy to read, programmable thermostat
- ☐ Order service for heating/AC system
- ☐ Install compact florescent lights where appropriate
- ☐ Reduce hot water temperature to 120°

COMMENTS:
